

Mary Bird

From: William Wagner
Sent: Monday, October 30, 2017 3:04 PM
To: Mary Bird
Subject: Ann Arbor Dog training proposal

Mary,

~~I quickly reviewed the plan for the proposed 18,000 building for the Ann Arbor Dog Training facility.~~

I don't see a proposal for a dry hydrant or water supply for fire suppression. The dry hydrant standard states that no part of a commercial, industrial and multi family cluster will be more than 1,000 feet from a dry hydrant with adequate water supply.

Thanks

Chief Wagner