## JAMES E. COX NORTHFIELD TOWNSHIP WATER POLLUTION CONTROL FACILITY 11500 LEMEN ROAD WHITMORE LAKE MICHIGAN PHONE 734-449-4159

To:	Northfield Township Board of Trustees
From:	Tim Hardesty Wastewater Treatment Plant Superintendent
Date:	March 14 <sup>th</sup> , 2017
 Subject:	February 2017 Monthly Report

- 2/1/17: Pulled pump #2 at Edmund pump station because of rags in the pump.
- 2/1/17: Repaired broken wire on generator at the Raymond pump station.
- 2/3/17: Call back to Shadow Woods pump station because of a float issue.
- 2/6/17: Started painting service building basement floor.
- 2/8/17: Finished painting the service building basement floor.
- 2/9/17: Repaired start and stop floats at East Shore #2 pump station.
- 2/13/17: Pulled rags out of pump #1 at the Elmcrest pump station.
- 2/16/17: Installed sewer marking posts along areas of force mains.
- 2/21/17: Installed new mechanical seal filters and lines for the filter influent, return sludge pumps, and the boiler feed water line.
- 2/21/17: Plugged sewer call at 50 N. Territorial Rd. The problem was in their line.
- 2/21/17: Pulled pump #1 at Elmcrest pump station and installed new wear ring.
- 2/22/17: Contracted a vacuum truck out to clean out a few of the pump station wet wells and vactor out the Intermediate clarifier.
- 2/27/17: Ran new flexible conduit for alarm on chlorine water feed pumps.
- 2/28/17: Pumped down aeration #3 for spring.

ŕ

February 2017 Daily Average Flow	.840MGD
February 2016 Daily Average Flow	.631MGD
Maximum February Daily Flow 2017	1.19MGD
<b>č</b>	
Maximum February Daily Flow 2016	.757MGD
Minimum February Daily Flow 2017	.645MGD
Minimum February Daily Flow 2016	.544MGD
6 – Month Average Flow	.719MGD
12 – Month Average Flow	.726MGD
Total Gallons Treated February 2017	23.510MG
<b>Total Gallons Treated February 2016</b>	18.289MG
Constant (Tor include on tor	0
Connections / Tap-ins' to system	0
Miss Dig Staking's	6
Overtime hours for the month:	42 hours